

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140090, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Electrical Inspection - Commercial	John Borns	Passed	Friday, August 22, 2014

Comments: OK TO COVER WHEN READY ELECTRICAL WIRING AND BOXES AT SERVING COUNTER AND AT CASH REGISTER COUNTER. ENSURE THAT BOXES ARE GROUNDED BEFORE INSTALLING DEVICES.