

FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:PRCOM20141072Date:Project Title:RESIDENCES AT NEW LONGVIEWApplicant:

Date: August 22, 2014 Applicant:

)1 SW KESSLER DR,
ES SUMMIT, MO 64081
MIX
LEASING OFFICE AND
CLUBHOUSE
Type VB (Unprotected)
194J

LYNN ELECTRIC & COMMUNICATIONS INC 725 N 2ND STREET, SUITE K LAWRENCE, KS 66044

Primary: (785) 843-5079

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Rejected

1. Building alarm plan is designed for having a sprinkler system, per the architect this building will not be a sprinklered building

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.