

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, August 26, 2014

Corrective Action Required

1	Misc 1	UNDERGROUND ELECTRICAL OK BELOW: -SECONDARY FROM TRANSFORMER TO SERVICE LOCATION -LIGHT POLE CIRCUITS PLACEMENT- OK AT BACK PARKING LOT -LIGHT POLE PIERS: PIERS AT REAR PARKING LOT AND SOUTH PARKING LOT-OK IN PROGRESS
---	--------	--

Footing Inspection - Commercial	Khanh Nguyen	Partial	Tuesday, August 26, 2014
--	--------------	---------	--------------------------

Corrective Action Required

1	Misc 1	-TRASH ENCLOSURE GRADE BEAM FOOTING OK PENDING ENGINEER LETTER. PLAN CALLS FOR SPREAD FOOTING
---	--------	--

Comments: