

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132440, Building Permit - Commercial
Address: 101 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, August 27, 2014

Partial Correction
1 Misc 1

OK TO COVER WHEN READY: ONE 3" AND ONE 4" SCH 40 PVC CONDUITS FROM BUILDING ENTRY TO POWER POLE AT SW CORNER OF SITE; 1" PVC CONDUIT TO LOCATIONS OF FIVE LIGHT POLES

Comments: