

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140913, Building Permit - Commercial  
Address: 110 NE SAINT LUKES BLVD, Unit:245, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Thursday, August 28, 2014

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING  
SYSTEMS @ FOLLOWING SPACES: 201-205; 207-208; 209; 210; 211; 212; 213;  
214; 215; 216; 217-224; 224A; 224B; 224C; 226; 227 N.S.; 229; 232; **[200;**  
**200A; 225; 225A; 225B; 230; 231; 234**

Partial Correction  
2 Misc 1

OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING  
SYSTEMS @ FOLLOWING SPACES: SOFFITS AT 217, 226, 227; SOFFIT OUTSIDE  
DOOR 2F200A; CEILING IN 2F206;

**Comments:**