

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #: PRCOM20141292

Address: 3680 NE AKIN DR, Unit:112, LEES SUMMIT, MO 64064

Inspected On: Friday, August 29, 2014

Inspected By: Khanh Nguyen

Expiration Date: 9/29/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Khanh Nguyen Temporary C of O Friday, August 29, Codes Commercial 2014

Corrective Action Required:

1 Misc 1 -RAISE THE EQUIPMENT FLOOR TO SAME LEVEL AS LANDING

**INSTALL HANDRAIL PER IBC 1009.15 AND 1012. THERE IS NO

EXCEPTION

-RECEPTACLE AT BREAK RM SINK: SUPPORT YOKE; BOX SHALL NOT BE RECESSED MORE THAN 1/4" BEHIND NON-COMBUSTIBLE WALL

FINISH, INSTALL BOX EXTENSION

**NEC 314.20

-RECEPTACLE WITHIN 6 FT OF BREAK RM SINK SHALL BE

GFCI-PROTECTED

**NEC 210.8(B)(5). NOTE THAT THERE IS NO EXCEPTION TO APPLY

TO THIS CASE