

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20132440, Building Permit - Commercial  
Address: 101 SW 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Passed	Wednesday, September 03, 2014
<b>Underground Plumbing Inspection - Commercial</b>	John Borns	Passed	Wednesday, September 03, 2014

**Comments:**

**OK TO COVER WHEN READY UNDER-SLAB PVC DWV PIPING.  
OK TO POUR WHEN READY GRADE BEAM FOR TRASH ENCLOSURE.**