

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20142405, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Wednesday, September 03, 2014

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY FRAMING FOR DOUBLE WALL AT S WALL OF  
1C215B PER NOTE 27 SHEET A1.0

**Comments:**