

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20140487, Building Permit - Residential
Address: 11608 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Plumbing Inspection - Residential	John Borns	Passed	Friday, September 05, 2014

Comments: NO ISSUES FOUND ON INSTALLATION OF SUMP PUMP AND DISCHARGE. RECOMMEND GFI PROTECTION ON EXISTING ELECTRICAL RECEPTACLE WHICH POWERS PUMP.