



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20141829, Public Works Infrastructure Permit - Residential
Residences at New Longview
Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection: Site Visit

Inspector:

Outcome: Partial

Date: 9/8/14

Comments: Went and looked at domestic water meter vault. 3" water line, told the contractor i would psi test the line and pull bac t samples. But mark would continue to look at construction of the line.
