

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20141418, Building Permit - Residential
Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, September 12, 2014

Corrective Action Required

1	Misc 1	FRAMING: -FIREBLOCKING: FB ALL FLOOR/CEILING PENETRATIONS; DUCT SPACE IN BREAKFAST/LIVING RM; SPACE AT SHARED BATH TUB; SPACE AT MASTER BED/BATH -INSTALL HANGER FOR TAIL JOIST AT CEILING FRAME OPENING ABOVE BREAKFAST -INSTALL SAFETY TEMPERED GLASS WINDOWS AT HYDROTUB ELECTRICAL: -COMPLETE ELECTRICAL AT: FRONT PORCH RECEPTACLE; GARAGE LIGHTS; FOYER RECEPTACLE; RECEPTACLE AT DUCT SPACE IN BREAKFAST/LIVING RM; SE BED AND BATH PLUMBING: -PROVIDE MIN. 15" CLEARANCE FROM MIDDLE OF TOILET TO FINISHED WALL AT SHARED BATH **OK TO INSULATE
---	--------	---

Electrical Service Inspection - Residential	Khanh Nguyen	Failed	Friday, September 12, 2014
--	--------------	--------	----------------------------

Corrective Action Required

1	Misc 1	-INSTALL A LISTED REBAR GROUNDING CLAMP APPROVED FOR ALLUMINUM CONDUCTOR
---	--------	--

Gas Service Inspection -	Khanh Nguyen	Failed	Friday, September 12, 2014
---------------------------------	--------------	--------	----------------------------

Residential**Corrective Action Required**

1

Misc 1

-PROVIDE MIN. 10 PSI PRESSURE FOR TESTING

Comments: