

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122453, Building Permit - Commercial
Address: 310 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Passed	Friday, September 12, 2014

Comments:

DUMPSTER ENCLOSURE FOOTING NW OF 1609 NW OBRIEN RD: PROVIDE CORNER BARS TO TIE TOGETHER CORNERS OF CAGES. ENSURE 3" COVERAGE FROM RE-BAR TO BOTTOMS AND BANKS OF TRENCH. OK TO POUR WHEN READY.