PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20141418, Building Permit - Residential Address: 1312 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

all corrective actions have been completed. Do not cover any work until approved. Inspection: Inspector: Outcome: Date: All Rough Inspection -Khanh Nguyen **Partial** Tuesday, September 16, 2014 Residential Corrective Action Required Misc 1 -INSTALL SAFETY TEMPERED GLASS WINDOWS AT HYDROTUB **OK TO ROCK **BEFORE ROCKING, HAVE THE MECHANICAL GUY TO FIX THE DUCTING PROTRUDING OUT FROM WALL IN SHARED BATHROOM **Electrical Service** Khanh Nguyen Failed Tuesday, September 16, 2014 **Inspection - Residential Corrective Action Required** Misc 1 -INSTALL A LISTED GROUNDING CLAMP APPROVED FOR ALLUMINUM CONDUCTOR **PROVIDE LISTING FOR THE GROUNDING CLAMP. Gas Service Inspection - Khanh Nguyen Tuesday, September 16, 2014 Passed Residential **Comments:**