

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122453, Building Permit - Commercial
Address: 310 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Tuesday, September 16, 2014

Partial Correction

1 Misc 1

SYSTEMS IN CRAWL SPACE SUBJECT TO APPROVAL WHEN READY FOR INSPECTION.

Partial Correction

2 Misc 1

SYSTEMS IN ATTIC OK EXCEPT OPEN ELECT J.BOXES NEAR NORTH END. INTEGRITY OF DRAFT WALLS YET TO BE IMPROVED. ALL SUBJECT TO APPROVAL AT FINAL INSPECTION.

Comments: