

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Thursday, September 18, 2014

Corrective Action Required

1 Misc 1

ABOVE CEILING OK BELOW:

- ADDITION 1ST FL RESTROOMS HARD LID CEILING
- SERVICE AREA SOFFIT AND COPYING RM
- ROOMS UNDER MEZZENINE
- BREAKROOM, TOOLS RM, AND BOTH RESTROOMS UNDER MEZZANINE
- SOFFIT ABOVE DISPLAY RM

****ELEVATOR EQUIPMENT RM-WRAP THE EXPOSED I BEAM WITH 5/8" TYPE X
ROCK, FC PENETRATIONS, MUD&TAPE SCREWS ON OUTER SIDE**

Comments: