

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140977, Building Permit - Commercial
Address: 800 NE JONES INDUSTRIAL DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Friday, September 19, 2014

Corrective Action Required

1 Misc 1

UNDERGROUND ELECTRICAL OK BELOW:
-SECONDARY FROM TRANSFORMER TO CT

PARKING LOTS LIGHT POLES:
-6 L. POLES ON EAST LOT

**NEED TO VERIFY THE UNDERGROUND CONDUITS MIN. 24" BURIAL DEPTH

Comments: