

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20130422, Building Permit - Commercial
Address: 3360 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Partial	Friday, September 19, 2014

Corrective Action Required

1	Misc 1	OK TO ROCK BELOW: -ALL 3RD FLOOR DWELLING UNITS, EXCEPT THE DEAD SPACES -3RD FL COMMON AREAS- OK TO ROCK CEILING 1ST LAYER. LEAVE OPEN AREA TO INSPECT DAMPERS
---	--------	--

Corrective Action Required

2	Misc 1	-ENGINEER REPORT REQUIRED FOR REPAIR OF ALL CUT I JOISTS ON 2ND FL
---	--------	--

Rated Assembly Inspection	Khanh Nguyen	Partial	Friday, September 19, 2014
----------------------------------	--------------	---------	----------------------------

Partial Correction

1	Misc 1	-GYPSUM TYPE X INSTALLED AT SHOWER WALL-2ND AND 3RD FL OK -STAIR WELLS -3RD FL: CEILING FURDOWN FOR MECHANICAL; CORRIDOR CEILING -2ND FL: CEILING FURDOWN FOR MECHANICAL-OK TO ROCK 1ST LAYER; CORRIDOR-OK TO ROCK 1ST LAYER
---	--------	---

Comments: