

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122453, Building Permit - Commercial
Address: 310 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, September 24, 2014

Partial Correction
1 Misc 1

OCCUPANCY STATUS: N-S WING UNITS 101-114 OK FOR OCCUPANCY

WORK IN UNIT 100 + E-W WING SUBJECT TO APPROVAL WHEN READY.

EXTERIOR WORK IN PROGRESS SUBJECT TO APPROVAL WHEN READY FOR INSPECTION.

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Wednesday, September 24, 2014
------------------------------------	---------	------------------	-------------------------------

Corrective Action Required
1 Misc 1

- post the numeric address of 310 on the front of the building
-replace the discharged extinguisher in the north end of corridor

Comments: