

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Thursday, September 25, 2014

Corrective Action Required

1	Misc 1	ABOVE CEILING OK BELOW: -ADDITION 1ST FL RESTROOMS HARD LID CEILING -SERVICE AREA SOFFIT AND COPYING RM -ROOMS UNDER MEZZENINE -BREAKROOM, TOOLS RM, AND BOTH RESTROOMS UNDER MEZZANINE -SOFFIT ABOVE DISPLAY AREA -ELEVATOR EQUIPMENT RM
---	--------	---

Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Thursday, September 25, 2014
---	--------------	---------	------------------------------

Corrective Action Required

1	Misc 1	UNDERGROUND ELECTRICAL OK BELOW: -SECONDARY FROM TRANSFORMER TO SERVICE LOCATION -LIGHT POLE CIRCUITS -LIGHT POLE PIERS: PIERS AT NORTH&SOUTH&EAST PARKING LOTS COMPLETED; -7 PIERS AT WEST LOT
---	--------	---

Rated Assembly Inspection	Khanh Nguyen	Partial	Thursday, September 25, 2014
--------------------------------------	--------------	---------	------------------------------

Corrective Action Required

1	Misc 1	-ELEVATOR SHAFT AND EQUIPMENT RM WALL -WEST STAIR WALL
---	--------	---

*INSPECTION OF PROTECTION OF ALL MEMBRANE PENETRATIONS WILL BE
DONE LATER AFTER ALL THE ELEVATOR HARDWARES ARE INSTALLED

Comments: