

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20140913  
**Address:** 110 NE SAINT LUKES BLVD, Unit:245, LEES SUMMIT, MO 64086  
**Inspected On:** Thursday, September 25, 2014  
**Inspected By:** John BornsJoe DirJoe Dir  
**Expiration Date:** 10/9/2014 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Thursday, September 25, 2014
<b>Occupancy Inspection - Fire</b>	Joe Dir	Temporary C of O	Thursday, September 25, 2014

**Corrective Action Required:**

1	Misc 1	- secure the loose alarm notification device (horn/strobe) back to the j-box in the corridor outside the main entrance of suite 245 - post the numeric/suite signage in the corridor outside the entrance doors to suite 245 - interior corridor emerg lights need to remain on with switches off during a power outage. install watt stoppers as needed.
---	--------	---

<b>Alarm Test</b>	Joe Dir	Passed	Thursday,
-------------------	---------	--------	-----------

September 25,  
2014