

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132440, Building Permit - Commercial
Address: 101 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Not Ready	Friday, September 26, 2014

Corrective Action Required

1	Misc 1	IN-WALL PLUMBING NOT APPROVED. STUD SHOES, NAIL GUARDS AND BOCA PLATES NOT COMPLETED.
---	--------	---

Rough Framing Inspection - Commercial	John Borns	Partial	Friday, September 26, 2014
--	------------	---------	----------------------------

Partial Correction

1	Misc 1	ROOF DECK AND PARAPET OK TO COVER WHEN READY.
---	--------	---

Comments: