

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20132419, Building Permit - Commercial  
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	<b>Not Ready</b>	Friday, September 26, 2014

Corrective Action Required

1	Misc 1	UNDERGROUND ELECTRICAL OK BELOW: -SECONDARY FROM TRANSFORMER TO SERVICE LOCATION -LIGHT POLE CIRCUITS -LIGHT POLE PIERS: PIERS AT NORTH&SOUTH&EAST PARKING LOTS COMPLETED; -7 PIERS AT WEST LOT
---	--------	--

<b>Gas Service Inspection - Commercial</b>	John Borns	Passed	Friday, September 26, 2014
--	------------	--------	----------------------------

**Comments: GAS PRESSURE TEST HELD STEADY AT >60 PSI FOR >20 MIN. REEASE SERVICE. VISUAL INSPECTION YET TO BE PERFORMED.**