

## **CODES ADMINISTRATION**

## Temporary Certificate of Occupancy

Permit #: PRRES20131165

Address: 602 NW REDBUD DR, Unit:B, LEES SUMMIT, MO 64081602 NW REDBUD DR, Unit:C, LEES SUMMIT, MO 64081602 NW REDBUD DR, Unit:A, LEES SUMMIT, MO 64081

Inspected On: Monday, September 29, 2014

Inspected By: John Borns

Expiration Date: 12/31/1899 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - John Borns Temporary C of O Monday,

Codes Residential September 29,

2014

OK FOR TEMPORARY OCCUPANCY THROUGH DATE STATED ABOVE AT UNITS "B" AND "C" CONTINGENT ON FOLLOWING CORRECTION BEING COMPLETED:

SECURE PEX TUBING TERMINATIONS AGAINST TORQUE WHEREVER CENTER OF VALVE IS >3" FROM PENETRATION THROUGH CABINET BASE OR BACK.