

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140038, Building Permit - Commercial
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Passed	Tuesday, September 30, 2014

Comments: RENOVATED AREA OK FOR USE & OCCUPANCY CONTINGENT ON:
1) CORRECT APPARENT HOT/NEUTRAL REVERSE AT ELECT RECEPT BEHIND ADMISSIONS DESK.
2) CHECK GLAZING IN ADMISSIONS OFFICE ENTRANCE DOORS TO ENSURE IT IS SAFETY GLAZING.
CLOSE PERMIT.