

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141214, Building Permit - Commercial
Address: 304 SW PERSELS RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Mark Harding	Partial	Tuesday, October 07, 2014

Partial Correction
1 Misc 1

SEE FOUNDATION PERMIT-(CLOSED)
DAILY INSPECTIONS ON UNDERSLAB ELECTRICAL .
CONTINUING INSPECTIONS-
-MAIN LINES TO HV4 PANEL
-MAIN PANEL LOCATION MOSTLY COMPLETE
-NO FLOOR SLAB BOXES AT THIS POINT
WORKING ON EAST SIDE-9-16-14
-WEST CENTER AREA
- COFFEE BAR
- 21 1-1/4", 1" & 3/4" CONDUITS DEEP-TRENCHED FROM ELECT RM (1048)
TO 12' N OF PANEL LV7

Comments: