

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142800, Building Permit - Commercial
Address: 1001 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Partial	Wednesday, October 08, 2014

Partial Correction
1 Misc 1

TWO 4" PVC PRIMARY CONDUITS TRENCHED >30" DEEP FROM POLE TO GEAR
AT SOUTH END OF BUILDING. NO ISSUES FOUND.

Partial Correction
2 Misc 1

ELECTROLYTIC GROUND ROD INSTALLED PER DRAWING. OK TO COVER WHEN
READY.

Comments: