LEE'S SUMMIT

## PUBLIC WORKS ENGINEERING DIVISION

## **Inspection Summary**

Permit #: PRPWFR20141829, Public Works Infrastructure Permit - Residential Residences at New Longview

Address: 3301 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:	Inspector:	Outcome:	Date:
PW-Fire Line - Flush	Jon Haley	Partial	Thursday, August 20, 2014
Corrective Action Required 1 Flushed water line for 10 minutes using a 4" fire hose.			
PW-Water Line - Coliform Test 1	Jon Haley	Passed	Thursday, October 09, 2014
PW-Water Line - Coliform Test 2	Jon Haley	Passed	Thursday, October 09, 2014

## **Comments:**

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1800 | 816.969.1810 Fax | cityofLS.net/Development