



PLANS REVIEW CONDITIONS

Permit No: PRCOM20141072 Date: October 10, 2014
Project Title: RESIDENCES AT NEW LONGVIEW Applicant:

Location: 3301 SW KESSLER DR, LYNN ELECTRIC & COMMUNICATIONS INC
LEES SUMMIT, MO 64081 725 N 2ND STREET, SUITE K
Type of Work: LAWRENCE, KS 66044
Occupancy Group: MIX
Description: LEASING OFFICE AND CLUBHOUSE Primary: (785) 843-5079
Construction Type: Type VB (Unprotected)
Map Page: 194J

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Brian Austerman

Rejected

1. Building alarm plan is designed for having a sprinkler system, per the architect this building will not be a sprinklered building

Alarm Plan Review

Reviewed By: Brian Austerman

Released for Construction

1. Building alarm plan is designed for having a sprinkler system, per the architect this building will not be a sprinklered building

10/10/14 Building will have a manual system with smoke detection. Also the other buildings will report alarms to this panel as supervisory/trouble

2. Delete outside horn strobe, building is not equipped with a sprinkler system

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.