

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142676, Building Permit - Commercial
Address: 255 NW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Tuesday, October 14, 2014

Corrective Action Required

1	Misc 1	SOUTH JAMB STUD AT DOOR OPENING DOES NOT EXTEND TO TOP TRACK. SCREW BOTH FLANGES OF JAMB STUDS AND CRIPPLES ABOVE DOOR FRAME TOP AND BOTTOM.
---	--------	--

Partial Correction

2	Misc 1	OK TO COVER WALLS AT LOBBY AND AT OFFICE 7 EXCEPT AT/ABOVE DOOR FRAME.
---	--------	---

Comments: