

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142405, Building Permit - Commercial
Address: 20 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Thursday, October 16, 2014

Occupancy Inspection - Fire	Joe Dir	Temporary C of O	Thursday, October 16, 2014
--	---------	------------------	----------------------------

Corrective Action Required

1	Misc 1	-storage room IC221 - permanetly locate the alarm notification device in the corridor -breakroom C183A make sure the smoke detector in the breakroom is secured in the ceiling once the ceiling tile is replaced
---	--------	---

Final Building Inspection - Commercial	John Borns	Partial	Thursday, October 16, 2014
---	------------	---------	----------------------------

Corrective Action Required

1	Misc 1	ELECT RECEPT ABOVE SINK IN 1C215A TO BE GFCI PROTECTED
2	Misc 1	FINISH PLUMBING TO BE COMPLETED IN 1C183A & 183B
3	Misc 1	RESOLVE FIRE DEPARTMENT ISSUES

Comments: PHASE 2 SPACES 1C124, 131, 183A, 183B, 215, 215A, 215B, & 221 OK FOR SET-UP AND USE AS SOON AS ABOVE ISSUES ARE CORRECTED/COMPLETED. CODES ADMIN RE-INSPECTION OF ITEMS (1) AND (2) WILL BE PERFORMED ON MONDAY 10/20.