

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140598, Building Permit - Commercial  
Address: 20 NE SAINT LUKES BLVD, Unit:200, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Not Ready	Thursday, October 16, 2014

Corrective Action Required  
3 Misc 1

IRC P2717.3 BACKFLOW PREVENTION AT DISHWASHER: DRAIN DISCHARGE LINE MUST RISE TO UNDERSIDE OF COUNTER AND BE SECURELY FASTENED (OR APPROVED ALTERNATE MEANS TO MAINTAIN HIGH POINT IN DISCHARGE LINE.)

Corrective Action Required  
4 Misc 1

NOT READY FOR FIRE DEPT FINAL. ELECTRICAL CONTRACTOR NOT PREPARED TO PROVIDE EMERGENCY SYSTEM TEST WITH FIRE DEPARTMENT.

**Comments:**