

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20132419, Building Permit - Commercial
Address: 2225 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Khanh Nguyen	Passed	Monday, October 20, 2014

Underground Plumbing Inspection - Commercial	Khanh Nguyen	Passed	Monday, October 20, 2014
---	--------------	--------	--------------------------

In-wall Inspection	Khanh Nguyen	Passed	Monday, October 20, 2014
---------------------------	--------------	--------	--------------------------

Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Monday, October 20, 2014
---	--------------	---------	--------------------------

Corrective Action Required

1 Misc 1

UNDERGROUND ELECTRICAL OK BELOW:
-SECONDARY FROM TRANSFORMER TO SERVICE LOCATION
-LIGHT POLE CIRCUITS
-LIGHT POLE PIERS: PIERS AT NORTH&SOUTH&EAST PARKING LOTS COMPLETED; PIERS AT WEST LOT

Above Ceiling Inspection	Khanh Nguyen	Passed	Monday, October 20, 2014
---------------------------------	--------------	--------	--------------------------

Comments: