PLANNING AND CODES ADMINISTRATION DEPARTMENT 220 SE GREEN STREET LEE'S SUMMIT, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142361, Building Permit - Commercial Address: 1001 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

In-wall Inspection John Borns Partial Tuesday, October 21, 2014

Partial Correction

1 Misc 1 OK TO COVER WHEN READY UNDER-SLAB PVC GREASE WASTE, SANITARY

DRAIN, WASTE, & VENT PIPING AT LOCATIONS: SPACE 105 WEST;

NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Underslab Electrical John Borns Partial Tuesday, October 21, 2014

Inspection -Commercial

Partial Correction

1 Misc 1 OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL

SYSTEMS AT FOLLOWING SPACES: SPACE 105 WEST WALL;

NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.

Comments: