

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141080, Building Permit - Commercial
Address: 3371 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	Mark Harding	Failed	Thursday, October 23, 2014

Corrective Action Required

1	Misc 1	electrical is approved- plumbing has been broken in numerous locations contractor is filling with gravel- do not cover plumbing at broken locations re-inspection required before covering. from elevator pit west and north is most of the broken locations.
---	--------	---

Comments: