

CITY OF LEE'S SUMMIT
 WATER UTILITIES DEPARTMENT - SUPPORT SERVICES DIVISION
 220 SE GREEN ST, LEE'S SUMMIT, MO 64063
 PHONE # (816) 969-1930 FAX # (816) 969-1935

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER: Lumber Warehouse
 SERVICE ADDRESS: 221 NW Chipman Rd.
 LOCATION OF ASSEMBLY: North of Bldg. in Vault

DATE OF TEST: 8-21-14 TIME: 11:00 A.M. P.M. SUPPLY PRESSURE: 90 LBS AIR GAP (2 x SUPPLY DIAMETER) SUPPLY IN. GAP IN. PASS FAIL

TYPE OF ASSEMBLY: DCVA RPBA DCDA RPDA PVB* (See bottom of form) MANUFACTURER: Watts MODEL: 757 DCDA SIZE: 6" SERIAL NUMBER: OE-0685

HEIGHT OFF FLOOR: 18 (NFT.) PROTECTION FROM: FREEZING YES NO FLOODING YES NO COMMENTS: NEW INSTALLATION YES NO

INITIAL TEST		PASSED	FAILED	FINAL TEST AFTER REPAIR		PASSED	FAILED
REDUCED PRESSURE PRINCIPLE ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>	REDUCED PRESSURE PRINCIPLE ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE OPENED AT <u> </u> PSID (2 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>	RELIEF VALVE OPENED AT <u> </u> PSID (2 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow <u> </u> PSID (5 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>	1ST CHECK held in direction of flow <u> </u> PSID (5 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1 st check - relief) <u> </u> PSID (3 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>	DIFFERENCE (1 st check - relief) <u> </u> PSID (3 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>

NOTE: Failure of any of the above items requires repair.

INITIAL TEST		PASSED	FAILED	FINAL TEST AFTER REPAIR		PASSED	FAILED
DOUBLE CHECK VALVE ASSEMBLY:		<input checked="" type="checkbox"/>	<input type="checkbox"/>	DOUBLE CHECK VALVE ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow <u>18</u> PSID (1 PSID or more)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	1ST CHECK held in direction of flow <u> </u> PSID (1 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input checked="" type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held in direction of flow <u>25</u> PSID (1 PSID or more)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held in direction of flow <u> </u> PSID (1 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight		<input checked="" type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>

NOTE: Failure of any of the above items requires repair.

APPLICATION: COMMERCIAL IRRIGATION FIRE LINE FIRE LINE BY-PASS METER# METER READ POINT OF USE

COMMENTS:

THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE

TESTED BY (PRINT SIGNATURE): Kevin Burns REPAIRED BY (PRINT SIGNATURE):
 COMPANY: Rainbow Construction FINAL TEST BY (PRINT SIGNATURE):
 MISSOURI CERTIFICATION NUMBER AND EXPIRATION DATE: 14-5748 OWNER OR OWNER'S REPRESENTATIVE: DATE: 8-21-14

* If an existing PVB is beyond repair and needs replacement, it should be replaced by a DCVA or RPBA to meet current State and City regulations. New PVB installations or replacements are not permitted.

CITY OF LEE'S SUMMIT
 WATER UTILITIES DEPARTMENT - SUPPORT SERVICES DIVISION
 220 SE GREEN ST, LEE'S SUMMIT, MO 64063
 PHONE # (816) 969-1930 FAX # (816) 969-1935

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER: Lumber Warehouse
 SERVICE ADDRESS: 221 Nw Chipman Rd
 LOCATION OF ASSEMBLY: North of Bldg. in Vault

DATE OF TEST: 8-21-14 TIME: 11:15 A.M. P.M. SUPPLY PRESSURE: 90 LBS AIR GAP (2 x SUPPLY DIAMETER) SUPPLY IN. GAP IN. PASS FAIL

TYPE OF ASSEMBLY: DCVA RPBA DCDA RPDA PVB* (See bottom of form) MANUFACTURER: Watts MODEL: 007 M3 SIZE: 3/4" SERIAL NUMBER: 209553

HEIGHT OFF FLOOR: 18 (ft.) PROTECTION FROM: FREEZING YES NO FLOODING YES NO COMMENTS: NEW INSTALLATION YES NO

INITIAL TEST	PASSED	FAILED	FINAL TEST AFTER REPAIR	PASSED	FAILED
REDUCED PRESSURE PRINCIPLE ASSEMBLY:	<input type="checkbox"/>	<input type="checkbox"/>	REDUCED PRESSURE PRINCIPLE ASSEMBLY:	<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE OPENED AT <u> </u> PSID (2 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	RELIEF VALVE OPENED AT <u> </u> PSID (2 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow <u> </u> PSID (5 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	1ST CHECK held in direction of flow <u> </u> PSID (5 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1 st check - relief) <u> </u> PSID (3 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>	DIFFERENCE (1 st check - relief) <u> </u> PSID (3 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>

NOTE: Failure of any of the above items requires repair.

INITIAL TEST	PASSED	FAILED	FINAL TEST AFTER REPAIR	PASSED	FAILED
DOUBLE CHECK VALVE ASSEMBLY:	<input checked="" type="checkbox"/>	<input type="checkbox"/>	DOUBLE CHECK VALVE ASSEMBLY:	<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow <u>1.2</u> PSID (1 PSID or more)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1ST CHECK held in direction of flow <u> </u> PSID (1 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held backpressure	<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held in direction of flow <u>1.2</u> PSID (1 PSID or more)	<input checked="" type="checkbox"/>	<input type="checkbox"/>	2ND CHECK held in direction of flow <u> </u> PSID (1 PSID or more)	<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUTOFF VALVE leak tight	<input checked="" type="checkbox"/>	<input type="checkbox"/>	NO. 2 SHUTOFF VALVE leak tight	<input type="checkbox"/>	<input type="checkbox"/>

NOTE: Failure of any of the above items requires repair.

APPLICATION: COMMERCIAL IRRIGATION FIRE LINE FIRE LINE BY-PASS
 METER# 94942006
 METER READ 010
 POINT OF USE

COMMENTS:

THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE

TESTED BY (PRINT SIGNATURE): Kevin Burns REPAIRED BY (PRINT SIGNATURE):
 COMPANY: Rainbow Construction FINAL TEST BY (PRINT SIGNATURE):
 MISSOURI CERTIFICATION NUMBER AND EXPIRATION DATE: 14-5748 OWNER OR OWNER'S REPRESENTATIVE: DATE: 8-21-14

* If an existing PVB is beyond repair and needs replacement, it should be replaced by a DCVA or RPBA to meet current State and City regulations. New PVB installations or replacements are not permitted.

Missouri state regulation 10 CSR 60-11.010(6)(E) requires testers to report results of tests and inspections to the customer and the water supplier.

DISTRIBUTION: WHITE - WATER SUPPLIER CANARY - OWNER OR TESTER