

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140231, Building Permit - Commercial
Address: 220 SW MAIN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Mike Copeland	Failed	Thursday, October 30, 2014

Corrective Action Required

1	Misc 1	-GAS PIPE SHOULD BE PAINTED TO RESIST CORROSION. WILL CHECK AT FINAL.
---	--------	---

Gas Service Inspection - Commercial	Mike Copeland	Passed	Thursday, October 30, 2014
--	---------------	--------	----------------------------

Comments: