

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140977, Building Permit - Commercial
Address: 800 NE JONES INDUSTRIAL DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Partial	Thursday, October 30, 2014

Corrective Action Required

1 Misc 1

UNDERGROUND ELECTRICAL OK BELOW:
-SECONDARY FROM TRANSFORMER TO CT
-CONDUITS BETWEEN LIGHT POLES

PARKING LOTS LIGHT POLES:
-6 L. POLES ON EAST LOT

**THE REMAINING LP AT WEST SIDE NEED GROUNDING.

In-wall Inspection	Khanh Nguyen	Partial	Thursday, October 30, 2014
---------------------------	--------------	---------	----------------------------

Corrective Action Required

2 Misc 1

IN-WALL OK:
-PARAPET WALLS

Corrective Action Required

1 Misc 1

IN-WALL ON 2ND FL:
-FIRESTOP ALL FLOOR PENETRATIONS
-INSTALL LISTED ANTI-HAMMERING ARRESTORS
-COMPLETE DUCTING THROUGH CHASES AND FIRESTOP AS REQUIRED

Comments: