

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142361, Building Permit - Commercial
Address: 1001 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - Commercial	John Borns	Partial	Monday, November 03, 2014

Partial Correction
1 Misc 1

G.W. AND SANITARY PIPING FROM BUILDING ENTRY, VENT, GREASE INTERCEPTOR, AND CONNECTION TO EXISTING SEWER SERVICE LINE APPROVED EXCEPT **BEDDING ROCK YET TO BE PLACED.**

Comments: