

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140231, Building Permit - Commercial  
Address: 220 SW MAIN ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection</b> <b>- Commercial</b>	John Borns	Passed	Thursday, November 06, 2014

**Comments: OBSERVED PREP FOR POUR OF ADA RAMP AND SIDEWALK AT SW CORNER OF BLDG.  
UNDER-SLAB CONDUIT PARTIALLY EXPOSED FOR INSPECTION. NO ISSUES FOUND.**