

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20140977, Building Permit - Commercial
Address: 800 NE JONES INDUSTRIAL DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Khanh Nguyen	Passed	Friday, November 07, 2014

In-wall Inspection	Khanh Nguyen	Partial	Friday, November 07, 2014
---------------------------	--------------	---------	---------------------------

Corrective Action Required

1	Misc 1	2ND FL IN-WALL: -FIRESTOP ALL FLOOR PENETRATIONS -COMPLETE DUCTING THROUGH CHASES AND FIRESTOP AS REQUIRED IN-WALL FOR ALL AREA NORTH OF NORTH STAIR WALL-OK
---	--------	---

Comments: