

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142412, Building Permit - Commercial

Address: 206 NW OLDHAM PKWY, LEES SUMMIT, MO 64081204 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Failed	Monday, November 10, 2014

Corrective Action Required

1 Misc 1

NEW WALLS AT FLOOR SINK:
IPC - PROTECTION OF COPPER PIPING AT PENETRATION OF STEEL FRAMING
MEMBERS: INSTALL GROMMETS OR OTHER APPROVED PROTECTION FROM
SHARP EDGES & DISSIMILAR METAL.

Corrective Action Required

2 Misc 1

OTHER NEW WALLS APPARENTLY CONSTRUCTED AND COVERED WITHOUT
INSPECTION AND APPROVAL.

Comments: