

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20142400, Building Permit - Commercial  
Address: 1047 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Mike Copeland Codes Commercial</b>	Mike Copeland	Failed	Thursday, November 13, 2014

Corrective Action Required  
1 Misc 1

NEC 511.12- ALL 125 V, SINGLE PHASE 15- AND 20- AMP RECEPTACLES  
SHALL HAVE GFCI PROTECTION.

**Comments:**