

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142361, Building Permit - Commercial
Address: 1001 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Friday, November 14, 2014

Corrective Action Required

1	Misc 1	STAND-OFF NEEDED AT BOTTOM OF VERTICAL RUN AT REAR WALL.
Partial Correction		
2	Misc 1	PIPING PRESSURE TEST SAID TO HAVE BEEN WITNESSED PREVIOUSLY BY ANOTHER INSPECTOR.

Comments: