

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20140977, Building Permit - Commercial  
Address: 800 NE JONES INDUSTRIAL DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Commercial</b>	Khanh Nguyen	Passed	Friday, November 14, 2014

<b>In-wall Inspection</b>	Khanh Nguyen	Partial	Friday, November 14, 2014
---------------------------	--------------	---------	---------------------------

### Corrective Action Required

1 Misc 1

#### 2ND FL IN-WALL:

-FIRESTOP ALL FLOOR PENETRATIONS

-COMPLETE DUCTING THROUGH CHASES AND FIRESTOP AS REQUIRED

IN-WALL OK BELOW: ALL AREA NORTH OF NORTH STAIR WALL; RESTROOMS  
AND AREA UNDER 2ND FL OFFICE

### Comments: