

Temporary Certificate of Occupancy

Permit #: PRCOM20122246
Address: 308 NW MURRAY RD, LEES SUMMIT, MO 64081
Inspected On: Monday, November 17, 2014
Inspected By: John BornsJoe DirJoe Dir
Expiration Date: 11/27/2014 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Monday, November 17, 2014

Partial Correction:
1 Misc 1 OK TO OCCUPY UNITS 520-529; [500-509;

SYSTEMS AT ATTIC AND BASEMENT YET TO BE INSPECTED.

Alarm Test	Joe Dir	Passed	Monday, November 17, 2014
-------------------	---------	--------	------------------------------

Corrective Action Required:

1 Misc 1	<ul style="list-style-type: none">- post the numeric address of building "308" on all four sides of the building- remove all dust covers from the corridor smoke detectors- terminatethe old wiring form the old corridor smoke detectors- mount the fire extinguisher in the corridor accessable from a 75'
----------	---

travel distance

**Occupancy Inspection -
Fire**

Joe Dir

Temporary C of O

Monday, November
17, 2014