

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20142361, Building Permit - Commercial  
Address: 1001 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Passed	Monday, November 17, 2014
<b>Occupancy Inspection - Fire</b>	Joe Dir	Passed	Monday, November 17, 2014
<b>Above Ceiling Inspection</b>	John Borns	Passed	Monday, November 17, 2014
<b>Gas Piping Inspection - Commercial</b>	John Borns	Passed	Monday, November 17, 2014

**Comments: NEW FOOD SERVICE AREA OK FOR USE. ROOFTOP GFCI ELECT RECEPT SHOULD HAVE IN-USE COVER PER NEC 406.8. CLOSE PERMIT.**