

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20143058, Building Permit - Commercial  
Address: 1701 NW BLUE PKWY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Failed	Tuesday, November 18, 2014

Corrective Action Required

1	Misc 1	G.E.C. CONNECTION TO GROUND ROD NOT FOUND.
---	--------	--

Corrective Action Required

2	Misc 1	ADDRESS MARKING TO BE CORRECTED.
---	--------	----------------------------------

**Comments:**