

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20142991, Building Permit - Commercial
Address: 516 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, November 19, 2014

Partial Correction
1 Misc 1

OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING LOCATIONS: #1; 2; 3; 6; 8; 4; 7; 9; 10; **11; 12; 13;**

INSPECTION OF TRENCHED CONDUIT IS PARTIAL SINCE SINCE SUBSTANTIAL PORTIONS HAVE BEEN TRENCHED AND COVERED WITHOUT APPROVAL.

Comments: