

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20142991, Building Permit - Commercial  
Address: 516 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	John Borns	Partial	Thursday, November 20, 2014

Partial Correction  
1      Misc 1

OK TO POUR WHEN READY CONCRETE LIGHT POLE BASE(S) AT FOLLOWING  
LOCATIONS: #1; 2; 3; 6; 8; 4; 7; 9; 10; 11; 12; 13; **14; 15; 16;**

INSPECTION OF TRENCHED CONDUIT IS PARTIAL SINCE SINCE SUBSTANTIAL  
PORTIONS HAVE BEEN TRENCHED AND COVERED WITHOUT APPROVAL.

**Comments:**