

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20122246, Building Permit - Commercial
Address: 308 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Friday, November 21, 2014

Partial Correction
1 Misc 1

OK TO OCCUPY UNITS 520-529; 500-509;

**UNITS 530-539 TO BE REINSPECTED BY FIRE DEPT AT 09:00 11/24. NO CODES
ISSUES REMIANING AT CORRIDOR OR UNITS**

SYSTEMS AT ATTIC AND BASEMENT YET TO BE INSPECTED BY JB 12/1.

Alarm Test	Joe Dir	Passed	Friday, November 21, 2014
-------------------	---------	--------	---------------------------

Occupancy Inspection - Fire	Joe Dir	Not Ready	Friday, November 21, 2014
----------------------------------------	---------	-----------	---------------------------

Corrective Action Required
1 Misc 1

2nd floor west wing-
keep all constuction debris, materials, related items off staiwys allowing for
exiting from all corridors
-remove dust covers from smoke detectors in the corridor
remove all constrution related items from the corridors and exit ways
-post the numeric address of 308 on all four sides of the building
- west stairway egress lighting needs to illuminate on D/C power
- don't corridor fire doors.

Comments: DO NOT ALLOW OCCUPANCY BEFORE FIRE DEPARTMENT APPROVES.